


Model Number	Nominal Size (W x H x D)	Actual Size (W x H x D)	Rated Airflow (CFM)	Initial Resistance (In. W.G.)	Media Area (Square Feet)
KP-STD2-1002	10X20X2	9-1/2X19-1/2X1-3/4	700	0.30	4.0
KP-STD2-2002	12X20X2	11-1/2x19-1/2x1-3/4	840	0.30	4.8
KP-STD2-2402	12X24X2	11-3/8x23-3/8x1-3/4	1000	0.30	5.7
KP-STD2-4002	14X20X2	13-1/2x19-1/2x1-3/4	980	0.30	5.5
KP-STD2-4502	14X25X2	13-1/2x24-1/2x1-3/4	1220	0.30	6.9
KP-STD2-5002	15X20X2	14-1/2x19-1/2x1-3/4	1050	0.30	6.0
KP-STD2-6602	16X16X2	15-1/2x15-1/2x1-3/4	890	0.30	5.3
KP-STD2-6002	16X20X2	15-1/2x19-1/2x1-3/4	1120	0.30	6.5
KP-STD2-6402	16X24X2	15-3/8x23-3/8x1-3/4	1340	0.30	7.5
KP-STD2-6502	16X25X2	15-1/2x24-1/2x1-3/4	1400	0.30	8.2
KP-STD2-8802	18X18X2	17-1/2x17-1/2x1-3/4	1125	0.30	6.6
KP-STD2-8002	18X20X2	17-1/2x19-1/2x1-3/4	1250	0.30	7.3
KP-STD2-8402	18X24X2	17-3/8x23-3/8x1-3/4	1500	0.30	8.7
KP-STD2-8502	18X25X2	17-1/2x24-1/2x1-3/4	1570	0.30	9.2
KP-STD2-0002	20X20X2	19-1/2x19-1/2x1-3/4	1400	0.30	8.0
KP-STD2-0402	20X24X2	19-3/8x23-3/8x1-3/4	1670	0.30	9.6
KP-STD2-0502	20X25X2	19-1/2x24-1/2x1-3/4	1750	0.30	10.1
KP-STD2-0302	20X30X2	19-1/2x29-1/2x1-3/4	2085	0.30	12.2
KP-STD2-4402	24X24X2	23-3/8x23-3/8x1-3/4	2000	0.30	11.8
KP-STD2-5502	25X25X2	24-1/2x24-1/2x1-3/4	2170	0.30	12.9



**STANDARD CONSTRUCTION**

- 100% Synthetic, Self-Supporting Media
- 10.16 Pleats per Foot
- (3) Pleat Stabilizer Straps, Upstream Side
- Media Pack Support Grid, Downstream Side
- Moisture Resistant Beverage Board Frame

**NOTES**

- MERV 8 per ASHRAE 52.2-2007.  
Tested at 492 FPM on 24x24x2 Nominal Size
- MERV-A 8-A ASHRAE 52.2-2007 Appendix J  
2. Final Resistance: 1.0" W.G.
- Rated Velocity: 500 FPM
- Class 2 Filter per U.L. Standard 900
- Maximum Operating Temperature: 150 deg. F

**Purolator**  
 100 River Ridge Circle  
 Jeffersonville, IN 47130  
 P: 866-925-2247  
 F: 502-961-0930  
 www.purolatorair.com

CONTACT FACTORY TO  
 VERIFY REVISION LEVEL

**TOLERANCES  
 UNLESS OTHERWISE SPECIFIED**

- FRACTIONAL -  
 DECIMAL -  
 ANGLES -

ALL DIMENSIONS IN INCHES

DRAWING NAME  
**KEY PLEAT STANDARD-CAPACITY 2" DEPTH**

APPROVED BY *K. Quinn* SPECIFICATION NO. MKT-P-00594 PAGE 1 OF 1

SCALE NONE DWG. SIZE A REVISION D REVISION DATE 05-06-11

CONFIDENTIAL - DO NOT COPY. THIS MATERIAL IS TRADE SECRET AND PROPRIETARY BEING EXCLUSIVELY OWNED BY CLC AIR. THE EXPRESSION OF THE INFORMATION CONTAINED HEREIN IS PROTECTED UNDER FEDERAL COPYRIGHT LAWS AND ALL COPYING IS PROHIBITED AND MAY BE SUBJECT TO CRIMINAL PENALTIES.